

3.0 Off-Site Heights Well No. 15 A

3.1 Plug well per Specifications, Rules and Regulations of TCEQ or under Texas Occupations Code Chapters 1901 and 1902/Standard for Capping and Plugging of Wells Paragraph 76.1004 amended effective December 1, 2003 Tex Reg 10468.

3.2 Blind-Flange all well discharge lines at 5 feet inside the property fence.

3.3 Remove and dispose wellhead foundation, pipe supports, concrete slabs, all discharge pipes to five feet inside property fence, electrical panels/cabinets and other electrical/mechanical equipment and devices.

3.4 Backfill and compact all excavations with select fill.

3.5 Add 80 cubic yards (more if necessary) of bank sand over select fill and grade to drain.

3.6 Hydro-mulch disturbed area.

3.7 Protect shrubs and trees.

Note: *Well No.15SB in the same site has been plugged. But discharge pipes are still in place. Well Contractor shall include removal and disposal of discharge pipes of Well No. 15SB when bidding.*



Off-Site Heights Well No. 15A