

ADDENDA #1

WORTHAM THEATER CENTER CHILLER REPLACEMENT

October 19, 2009

TO:

Deyanira Rodriguez
City of Houston
510 Preston, 4th Floor
Houston, TX 77002



1. **Sheet M1.0**
 - a. Added note 7 to demo existing refrigerant relief piping roof penetration.
2. **Sheet M2.0**
 - a. Relocated existing and new refrigerant relief piping to not be adjacent to boiler room intake louver.
3. **Sheet M3.0**
 - a. Revised detail 1 to clearly show inertia base and flex connectors.
 - b. Revised detail 4 to correctly show refrigerant piping penetration of concrete roof.
 - c. Added VFD's to pump and fan schedule.
 - d. Corrected typo in chiller schedule.
4. **Sheet M4.0**
 - a. Added definition of substantial completion.
5. **Sheet M5.0**
 - a. Added specification for refrigerant relief piping.
 - b. Revised specification for expansion fittings.
 - c. Revised specification for pump and fan VFD's.
6. **Sheet M6.0**
 - a. Revised specification for warranty and factory test.
7. **Sheet E2.0**
 - a. Revised to change starters to VFD's.
8. **Sheet E3.0**
 - a. Revised to change starters to VFD's.

-----END-----